



Lead in Drinking Water – Public and Nonpublic Schools

Updated in response to legislation effective as of June 1, 2021

IMPORTANT NOTICE: ELEVATED LEAD WATER SAMPLE RESULT(S)

Centreville Middle School

September 24, 2024

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On **May 17, 2024**, **42** lead water samples were collected from **Centreville Middle School**. Of these **42** lead water samples, **29** had levels of lead exceeding the State's revised action level of 5 parts per billion (ppb) (*formerly 20 ppb; 5 ppb effective June 1, 2021*) for lead in drinking water in school buildings.

The elevated lead results from the sample(s) collected at **Centreville Middle School** were as follows:

ID	CMS Location	PPB		ID	CMS Location	PPB
1	Nurse's Office	11.7		62	Room B-6	10.9
3	Staff Workroom	11.8		63	Classroom B8	51.7
12	Art #1 Front wall	12.1		64	Room B-7	11.5
13	Art#2 Island Front	366		65	Room B-1	8.6
15	Art #4 Rear	7.5		66	Room B-9	7.8
16	Art Work Storage Room	190		69	Media Work Room	9.3
17	Art Office	32.2		73	Room A-10	12.6
23b	Classroom 1A1	44.4		74	Room A-11	7.2
23c	Classroom 1A2	5.9		75	Room A-6	6.2
35	Teachers' Lounge	11.7		80	Room A-3	9.8
37	Room C9	20.7		81	Room A-1	49.3
38	Room C12	93		82	Room A-12	10.6
40	Classroom C-6	6.1		93	Room C-13	15.5
56	Room C3	112		94	Room A-14	7.3
57	Room 161	6.7				

ACTION LEVEL (AL)

Effective June 1, 2021, the State's AL for lead in drinking water samples collected from outlets in school buildings has been lowered to 5 ppb. The AL is the concentration of lead which, if exceeded, triggers required remediation of drinking water outlets.



QUEEN ANNE'S COUNTY PUBLIC SCHOOLS

Where Our Future Begins

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These sources include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

Follow up samples will be collected at a later date and signage will be posted indicating non-consumable water.

NEXT STEPS

The next steps will be determined by the new results received which may be a fixture replacement, a filter installed, non-consumable sticker will be posted, and/or capping off the fixture.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

For additional information, please contact the **Board of Education at 410.758.2403 x 140**. Additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.